

Annual Drinking Water Quality Report

TX1260001

CITY OF ALVARADO

Annual Water Quality Report for the period of January 1 to December 31, 2012

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:

Name Clint Davis

Phone 817-790-3351

CITY OF ALVARADO is Ground Water

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono () - - .

Public Participation Opportunities: 7/15/13, 7:00 p.m. at City Hall, 104 W. College Street, Alvarado

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW>

Source Water Name	Type of Water	Report Status	Location
1 - 110 W SHELTON	110 W SHELTON	GW	Y
2 - 312 E SHELTON	312 E SHELTON	GW	Y
4 - 801 ELWOOD COURT	801 ELWOOD COURT	GW	Y
6 - 805 RUSK	805 RUSK	GW	Y
9 - 12110 GLENWOOD DR	12110 GLENWOOD DR	GW	Y
GW FROM JOHNSON COUNTY SUD	CC FROM TX1260018	GW	

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	07/15/2010	1.3	1.3	0.12	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	07/15/2010	0	15	1.4	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)

Water Quality Test Results

ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppt	parts per trillion, or nanograms per liter (ng/L)
ppq	parts per quadrillion, or picograms per liter (pg/L)

Chemical Used: Chlorine

Average Level of Quarterly Data: 1.2 mg/l

Lowest Result of a Single Sample: 0.7 mg/l

Highest Result of a Single Sample: 4.0 mg/l

Source of the Chemical: Chlorine gas

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact Clint Davis.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Total Trihalomethanes (TTHM)	06/21/2010	5.4	0 - 5.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	08/08/2011	1.35	0 - 1.35	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	08/08/2011	0.0603	0.0188 - 0.0603	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	08/08/2011	6.68	0 - 6.68	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Cyanide	08/08/2011	13	13 - 13	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
Fluoride	10/26/2011	1.13	1.13 - 1.13	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2012	0.065	0 - 0.065	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	08/08/2011	0.563	0 - 0.563	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Thallium	08/08/2011	0.592	0 - 0.592	0.5	2	ppb	N	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	2012	1	1 - 1	0	5	pCi/L	N	Erosion of natural deposits.

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Di (2-ethylhexyl) phthalate	11/12/2009	1.63	0 - 1.63	0	6	ppb	N	Discharge from rubber and chemical factories.

Violations Table

Public Notification Rule			
The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).			
Violation Type	Violation Begin	Violation End	Violation Explanation
PUBLIC NOTICE RULE LINKED TO VIOLATION	06/10/2012	2012	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.

Total Coliform			
Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MONITORING (TCR), ROUTINE MINOR	02/01/2012	02/29/2012	We failed to complete all the required tests of our drinking water for the contaminant and period indicated.

Explanation: Samples were taken and were found to be in compliance; however, they were taken after the required date. Original samples were not picked up by laboratory facility in a timely manner.

LCRA Environmental Laboratory Services

Date: 27-Jun-11

CLIENT: Johnson Co Rural WSC
 Lab ID: 1106049-028
 Project: WS 1260018
 Matrix: DRINKING WATER
 Collection Date: 5/31/2011 10:51:00 AM

Facility: EP013
 Sample Point: TRT-TAP
 Sample Location:
 TCEQ Sample ID: 1144620

Analyses	Result	Qual	MCL	LOD	PQL	Units	DF	BatchID	Date Analyzed
VOLATILES BY GCMS			E524.2			Analyst: BC			
REGULATED COMPOUNDS									
Benzene	< 0.50		5	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
Carbon Tetrachloride	< 0.50		5	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
Monochlorobenzene	< 0.50		100	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
o-Dichlorobenzene	< 0.50		600	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
para-Dichlorobenzene	< 0.50		75	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
1,2-Dichloroethane	< 0.50		5	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
1,1-Dichloroethylene	< 0.50		7	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
cis-1,2-Dichloroethylene	< 0.50		70	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
trans-1,2-Dichloroethylene	< 0.50		100	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
1,2-Dichloropropane	< 0.50		5	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
Ethylbenzene	< 0.50		700	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
Dichloromethane	< 0.50		5	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
Styrene	< 0.50		100	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
Tetrachloroethylene	< 0.50		5	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
Toluene	< 0.50		1000	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
1,2,4-Trichlorobenzene	< 0.50		70	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
1,1,1-Trichloroethane	< 0.50		200	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
1,1,2-Trichloroethane	< 0.50		5	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
Trichloroethylene	< 0.50		5	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
Vinyl chloride	< 0.50		2	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
m,p-Xylene	< 0.50			0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
o-Xylene	< 0.50			0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM
Xylenes, Total	< 0.50		10000	0.50	0.50	µg/L	1	82347	6/2/2011 4:05:00 PM